


12.3.8 v.2

SUBSURFACE STORAGE PLAN NTS

FIGURE 1



TYPICAL SECTION NTS

NOTE:

- SELECT FILL - SHALL CONSIST OF WELL-GRADED ROCK, OR ROCK AND COARSE SAND FILL. FINE SAND, OR FILL HAVING A HIGH PROPORTION OF FINES WILL NOT BE ACCEPTED. IF NOT AVAILABLE, FILTER FABRIC SHALL BE SPECIFIED FOR THE FILL/DRAIN ROCK INTERFACE.
- AFTER DRAIN ROCK HAS BEEN PLACED, TO DESIRED ELEVATION, WASH DOWN WITH CLEAN WATER TO ALLOW FOR INITIAL SETTLEMENT. IF SETTLEMENT OCCURS ADD ADDITIONAL DRAIN ROCK TO REQ'D. ELEVATION.

USEPA SF




1272987



KLEIN CONSULTING ENGINEERS
Civil Engineers/Planners/Surveyors
Forest Grove, Oregon

FIGURE 2



MANHOLE - HEADER
ASSEMBLY
NTS



KLEIN CONSULTING ENGINEERS
Civil Engineers/Planners/Surveyors
Forest Grove, Oregon